



Protect Yourself from COVID-19
"No carelessness until there is no cure"
(i) Wear your mask properly
(ii) Wash your hands regularly
(iii) Maintain 6 feet of physical distance

Haryana Public Works (B&R) Department
Jagadhri Provincial Division, PWD B&R BR., Yamuna Nagar
Telephone No. 01732-237834
E-Mail pwd-eeepd-yamunanagar@hry.nic.in, exenyamunanagar@yahoo.com

To

The Principal
P.M Shri Govt. Senior Secondary School,
Mussimbal-0185, Yamuna Nagar.

Memo No. 7928

Dated: 09/2/24

Subject: Regarding building Safety Certificate for CBSE Affiliation of PM Shri GSSS Mussimbal.

Ref: - 3840/24 dt 29-1-2024

In this connection, it is intimated that the building of PM Shri G.S.S.S Mussimbal has been inspected by Sub Divisional Engineer, Provl. Sub Division No. 2, PWD B&R Br., Yamuna Nagar alongwith JE concerned and has reported that no structural design and drawing duly proof checked from the approved source/reputed agency like Punjab Engg. College Chandigarh, NIT Kurukshetra and IIT Roorkee etc. has been supplied alongwith the application and on the visual/physical inspection carried out by the SDE, the building apparently appears to be safe presently. However, as far as seismic factor is concerned, the advice of structural consultant may be sought.

This is for your kind information and further necessary action please.

D. A. /Nil

Executive Engineer,
Jag. Provl Divn. PWD B&R Br.,
Yamuna Nagar

Endst No. 7929

Dated:- 09/2/24

Copy of the above is forwarded to the Sub Divisional Engineer, Provl. Sub Divn. No.2, PWD B&R Br Yamuna Nagar with reference to his office letter no. 2745 dated 05.02.2024.

D. A. /Nil

Executive Engineer,
Jag. Provl Divn. PWD B&R Br.,
Yamuna Nagar

PRINCIPAL
PM SHRI GSSS MUSSIMBAL-0185
B. BILASPUR (YNR)

A I to HDM

may file after putting reference